



SUPERELEVATED CURB AND GUTTER

GENERAL NOTES:

- 1. FILLER MATERIAL SHALL BE 12-20mm THICK PIECE OF FULL DEPTH AND WIDTH OF JOINT MEETING OPSS 1308 (EXCLUDING CORK FILLER)
- 2. MAXIMUM SPACING OF JOINTS:

3m ON CIRCULAR SECTION WITH RADIUS LESS THAN 9m; 4.9m ELSEWHERE.

- 3. CONTRACTION JOINTS FOR ASPHALT SURFACES TO BE SPACED 5m AND COINCIDE WITH THE CONTRACTION JOINTS FOR CONCRETE PAVEMENTS.
- 4 CROSS FALL OF GUTTER SHALL CONFORM TO PAVEMENT CROSS FALL AT CATCH BASIN.
- 5. FOR COMPOSITE PAVEMENT THE DEPTH OF CONCRETE CURB SHALL BE ADJUSTED TO THE DEPTH OF CONCRETE PAVEMENT.
- 6. ALL WORK SHALL CONFORM TO CITY OF WINDSOR SPEC. S-5

STANDARD & SUPERELEVATED CURB & GUTTER FOR COLLECTOR & ARTERIAL ROADS DR'N BY: L.E.B. DATE: MARCH 2017 REVISION: S.R. CH'KD BY: M.C. CH'KD BY: P.U. PASSED BY: AS-208A

CITY OF WINDSOR

ENGINEERING DEPARTMENT