



GENERAL NOTES:

- ① $A = D_i \times /4$ BUT NO LESS THAN 150mm, OR AS DIRECTED BY CITY ENGINEER.
- ② SEWER STONE REFERS TO COARSE AGGREGATE FOR HL4 ASPHALT PER OPSS 1003 APP-D.
- ③ COVER MUST BE COMPACTED TO 100% SPMD
- ④ IF THE NATIVE, UNDISTURBED SOIL IS A FINE GRAINED, NON-COHESIVE MATERIAL, THE USE OF A GEOTEXTILE FABRIC SEPARATION MAYBE REQUIRED BETWEEN THE NATIVE MATERIAL AND THE SEWER STONE BEDDING MATERIAL

NOT TO SCALE



CITY OF WINDSOR

ENGINEERING DEPARTMENT

**CLASS 'B' BEDDING DETAIL
VARIOUS CASES**

DR'N BY: MF, AZ

DATE: MAR, 2004

REV. DATE: MAR, 2024

CH'KD BY(ENG): PM, JH

CH'KD BY(GEO/OPS):PJU, AL

PASSED BY: FM

CITY ENGINEER

AS-310B