



**THE CORPORATION OF THE CITY OF WINDSOR
OFFICE OF THE CITY SOLICITOR**

ALEX VUCINIC
Manager of Purchasing

Elaine Castellan
Purchasing Supervisor

(519) 255-6272
TELEPHONE NUMBER

**ADDENDUM NO. 2
TENDER NO. 40-19
1314 DROUILLARD ROAD DEMOLITION**

April 1, 2019

This addendum amends and forms part of the Tender Documents. The bidder shall insert the addendum behind the cover page of the Tender Documents.

QUESTIONS/ANSWERS

Question #1:

The specifications indicate that a black vinyl, 6-gauge chain link fence with 1" mesh is to be provided. The 1-inch mesh size does not appear to be correct, please provide the correct mesh size. Also specify the size of posts that will be required.

Answer: The black chain-link fence (130'-0" and 4'-0" high) is to be 6-gauge with 2-inch mesh including black fence posts – minimum 2-3/8 –inch OD line posts and 2-7/8-inch-OD corner and pull posts, with 1-5/8-inch –OD top rails. A revised Schedule 1- Pricing is attached.

Except for the contents of this addendum, all other terms and conditions of this tender remain the same.

END OF ADDENDUM NO. 2

Yours truly,

THE CORPORATION OF THE CITY OF WINDSOR

Elaine Castellan

Elaine Castellan
Purchasing Supervisor

EC/jm

**ADDENDUM NO. 2
TENDER NO. 40-19
1314 DROUILLARD ROAD DEMOLITION**

April 1, 2019

I hereby acknowledge receipt of Addendum No. 2 to the Tender No. 40-19 (4 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the _____ day of _____, 20_____.

Signature

Name (Printed)

Company Name

***NOTE: You are required to acknowledge this addendum with your TENDER submission.**

**PLEASE FAX BACK TO (519) 255-9891 OR E-MAIL @ purchasing@citywindsor.ca SIGNED
ACKNOWLEDGEMENT SHEET ASAP**

Attn: Purchasing Department

DEMOLITION – 1314 DROUILLARD RD

SCHEDULE 1 – PRICING (Revised)

ITEMIZED PRICE	
DEMOLITION SCOPE	PRICE
Asbestos, Lead, Mercury, and Silica (if applicable) Removal & Disposal	\$
Demolition, Removal & Disposal of the 1314 Drouillard Rd building and associated infrastructure, inclusive of <u>All Works</u> noted in the Contract Documents not otherwise specifically listed in this Pricing Schedule	\$
Compacted Backfill and Grading of the Site	\$
Topsoil and Seed Restoration (per City of Windsor Standard Specifications S-15 & S-34)	\$
Labor and material for a black vinyl (130'-0" long and 4'-0" high), 6 gauge, chain link fence with 2" mesh including black fence posts (Provisional Item – Quantity will be paid per foot actually installed, unit rate shall be value presented divided by 130).	\$
TOTAL TENDERED PRICE (excluding HST)	\$

DEMOLITION – 1314 DROUILLARD RD

Complete the following charts and submit with tender.

SUBCONTRACTORS:

We propose to use the following sub-contractors, the portion of the work to be performed by each being as indicated with no more than one sub-contractor being proposed for any such portion, all in accordance with the Named Subtrades Policy (Instructions to Bidders Appendix “C”)

SUB-CONTRACTORS LIST

DEMOLITION RELATED ITEM	SUBCONTRACTOR/ENGINEER
Asbestos Abatement Contractor	
Lead Abatement Contractor	
Mercury Abatement Contractor	
Non-Hazardous Waste Removal Contractor	
Trucking Services	
Demolition Contractor	

- END OF SCHEDULE 1 – PRICING -