



**THE CORPORATION OF THE CITY OF WINDSOR
OFFICE OF THE CITY SOLICITOR**

ALEX VUCINIC
Manager of Purchasing

Elaine Castellan
Purchasing Supervisor

(519) 255-6272
TELEPHONE NUMBER

**ADDENDUM NO. 1
TENDER NO. 37-19
BRIDGEVIEW PARK PATHWAY AND PARKING LOT**

March 4, 2019

This addendum amends and forms part of the Tender Documents. The bidder shall insert the addendum behind the cover page of the Tender Documents.

QUESTIONS & ANSWERS:

1. The existing gravel alley is shown to be removed along the entire length on the east side but only a small section on the west side; Is this correct that only part of the west alley is being removed?

Correct, the East side ally has been closed and is to be removed fully. The West side alley is still functional and will be required to keep open and free of any equipment. Project Manager will mark off location. Length of area is about 60m North of the South property line

2. What material is being used to fill the excavated areas of the alleys? Can the materials from the new path construction be used as fill or is this being completed by others?

Yes, the material from the new pathway can be used to fill in the excavated area, providing the material is clean and free of debris.

3. Can the materials from the new pathway be level on site or does all excavated materials have to be disposed off site?

Any fill that is not used as fill on-site shall be disposed of off-site at Norfolk and California.

4. Who is responsible for restoration, topsoil and seed or sod along the new path and parking lot and in the excavated alley areas?

Final restoration, topsoil and seed along new path is not in this Contract. Rough Grading is required for the Bridgeview Contract.

5. Is there any form of separation between the new parking lot and the adjacent pathways on either side?

Yes, there is a curb around the perimeter of the parking lot.

6. The only difference between Bid Form – Price Schedule Item A11 and Item D3 for the asphalt pavement, is being done in 1 or 2 lifts; Will only one of these items will be used?

Yes, D3 is a provisional price. Refer to Instructions to Bidders - Section 13, and General Conditions – Section 10. Only one of these items will be completed and it will be dependant on budget.

Except for the contents of this addendum, all other terms and conditions of this tender remain the same.

END OF ADDENDUM NO. 1

Yours truly,

THE CORPORATION OF THE CITY OF WINDSOR

Elaine Castellan

Elaine Castellan
Purchasing Supervisor

EC/sf

**ADDENDUM NO. 1
TENDER NO. 37-19
BRIDGEVIEW PARK PATHWAY AND PARKING LOT**

March 4, 2019

I hereby acknowledge receipt of Addendum No. 1 to the Tender No. 37-19 (3 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the _____ day of _____, 20_____.

Signature

Name (Printed)

Company Name

***NOTE: You are required to acknowledge this addendum with your TENDER submission.**

**PLEASE FAX BACK TO (519) 255-9891 OR E-MAIL @ purchasing@citywindsor.ca SIGNED
ACKNOWLEDGEMENT SHEET ASAP**

Attn: Purchasing Department