



**THE CORPORATION OF THE CITY OF WINDSOR
OFFICE OF THE CITY SOLICITOR**

ALEX VUCINIC

Manager of Purchasing

Elaine Castellan

Purchasing Supervisor

(519) 255-6272

TELEPHONE NUMBER

**ADDENDUM NO. 2
DOMESTIC HOT WATER TANKS & CONTROL VALVE REPLACEMENT - WJF
RFT NO. 141-18**

SEPTEMBER 12, 2018

This addendum amends and forms part of the Tender Documents. The Bidder shall insert the addendum behind the cover page of the Tender Documents.

QUESTIONS & ANSWERS:

1/ There are two models of the Viessmann Vitocell 300-V available; Series EVI and EVIA. Which model tanks we are to provide?

The tanks are: Viessmann Vitocell 300-V, 79 USG "EVIA".

2/ Can you provide information on the three-way valves and actuators, as follows; Has the 6" three-way size been confirmed (it was covered with insulation at the time of the walk through)? Are the actuators direct acting or reverse acting? What is the operating pressure of each system?

Valve #148 is a 6" control valve with direct acting actuator 3-way valve

Valve #155 is a 6" control valve with direct acting actuator 3-way valve

Valve #171 is a 3" control valve with direct acting actuator 3-way valve

Operating Pressure of each system is 80 PSI.

3/ What kind of downtime will be allowed for the change out of the valves? Can we assume that downtime will need to include start-up and commissioning of the new valves?

All work must be performed between 8am and 4pm, and includes start-up and commissioning of systems.

4/ Please provide some clarification regarding the mandatory use of Honeywell for the connections to the actuators as discussed at the walk through. Will Honeywell have to commission the valves?

Honeywell's Scope of Work will be to assist with commissioning of the valves and subject to any of the existing sensors being damaged during installation Honeywell will ensure newly installed Hot Water Tanks will show on the Building Automation System.

Except for the contents of this addendum, all other terms and conditions of this Tender remain the same.

END OF ADDENDUM NO. 2

Yours truly,

THE CORPORATION OF THE CITY OF WINDSOR

Elaine Castellan

Elaine Castellan
Purchasing Supervisor

EC/sf

**ADDENDUM NO. 2
DOMESTIC HOT WATER TANKS & CONTROL VALVE REPLACEMENT - WJF
RFT NO. 141-18**

SEPTEMBER 12, 2018

I hereby acknowledge receipt of Addendum No. 2 to Tender No. 141-18 (3 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the _____ day of _____, 20_____.

Signature

Name (Printed)

Company Name

***NOTE: You are required to acknowledge this addendum with your TENDER submission.**

PLEASE FAX BACK TO (519) 255-9891 OR E-MAIL @ purchasing@citywindsor.ca
SIGNED ACKNOWLEDGEMENT SHEET ASAP

Attn: Purchasing Department