



**THE CORPORATION OF THE CITY OF WINDSOR
OFFICE OF THE CITY SOLICITOR**

ALEX VUCINIC

Manager of Purchasing

Elaine Castellan

Purchasing Supervisor

(519) 255-6272

TELEPHONE NUMBER

**ADDENDUM NO. 3
DOMESTIC HOT WATER TANKS & CONTROL VALVE REPLACEMENT - WJF
RFT NO. 141-18**

SEPTEMBER 14, 2018

This addendum amends and forms part of the Tender Documents. The Bidder shall insert the addendum behind the cover page of the Tender Documents.

CORRECTION:

Valve #148 is a 6" control valve with direct acting actuator 3-way valve
Valve #155 is a 6" control valve with direct acting actuator 3-way valve
Valve #171 is a 3" control valve with direct acting actuator 3-way valve

Above sizes issued in Addendum No. 2 are incorrect, and are to be REVISED, as follows;

Valve #148 is a 5" control valve with direct acting actuator 3-way valve
Valve #155 is a 5" control valve with direct acting actuator 3-way valve
Valve #171 is a 2.5" control valve with direct acting actuator 3-way valve

Except for the contents of this addendum, all other terms and conditions of this Tender remain the same.

END OF ADDENDUM NO. 3

Yours truly,

THE CORPORATION OF THE CITY OF WINDSOR

Elaine Castellan

Elaine Castellan
Purchasing Supervisor

EC/sf

**ADDENDUM NO. 3
DOMESTIC HOT WATER TANKS & CONTROL VALVE REPLACEMENT - WJF
RFT NO. 141-18**

SEPTEMBER 14, 2018

I hereby acknowledge receipt of Addendum No. 3 to Tender No. 141-18 (2 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the _____ day of _____, 20_____.

Signature

Name (Printed)

Company Name

***NOTE: You are required to acknowledge this addendum with your TENDER submission.**

PLEASE FAX BACK TO (519) 255-9891 OR E-MAIL @ purchasing@citywindsor.ca
SIGNED ACKNOWLEDGEMENT SHEET ASAP

Attn: Purchasing Department