



**THE CORPORATION OF THE CITY OF WINDSOR  
OFFICE OF THE CITY SOLICITOR**

**ALEX VUCINIC**

**Manager of Purchasing**

**Elaine Castellan**

**Purchasing Supervisor**

**(519) 255-6272**

**TELEPHONE NUMBER**

---

**ADDENDUM NO. 2  
TENDER NO. 164-19  
FIRE TRAINING FACILITY – WOMEN’S WASHROOM UPGRADE**

**December 13, 2019**

---

This addendum amends and forms part of the Tender Documents. The bidder shall insert the addendum behind the cover page of the Tender Documents.

**CLARIFICATION TO SPECIFICATIONS:**

Refer to the detail titled “Typical Exhaust Fan/Vent/Duct on sheet A-1. The existing 24” x 24” roof curb for the existing roof fan can be reused, with no modifications, for the new specified exhaust fan – no modifications are required to the existing roof opening or roof curb construction. The removal and reinstallation of the exhaust fan should be properly sealed and flashed to match or exceed the level of the existing condition.

Except for the contents of this addendum, all other terms and conditions of this tender remain the same.

***END OF ADDENDUM NO. 2***

Yours truly,

**THE CORPORATION OF THE CITY OF WINDSOR**

***Elaine Castellan***

Elaine Castellan  
Purchasing Supervisor  
EC/jm

---

**ADDENDUM NO. 2  
TENDER NO. 164-19  
FIRE TRAINING FACILITY – WOMEN’S WASHROOM UPGRADE**

**December 13, 2019**

---

I hereby acknowledge receipt of Addendum No. 2 to the Tender No. 164-19 (2 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_\_.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Name (Printed)

\_\_\_\_\_  
Company Name

**\*NOTE: You are required to acknowledge this addendum with your TENDER submission.**

**PLEASE FAX BACK TO (519) 255-9891 OR E-MAIL @ [purchasing@citywindsor.ca](mailto:purchasing@citywindsor.ca) SIGNED  
ACKNOWLEDGEMENT SHEET ASAP**

**Attn: Purchasing Department**