



**THE CORPORATION OF THE CITY OF WINDSOR
OFFICE OF THE CITY SOLICITOR**

ALEX VUCINIC
Manager of Purchasing

Elaine Castellan
Purchasing Supervisor

(519) 255-6272
TELEPHONE NUMBER

**ADDENDUM NO. 1
TENDER NO. 65-19
HAWTHORNE PEDESTRIAN BRIDGE CONSTRUCTION**

April 12, 2019

This addendum amends and forms part of the Tender Documents. The bidder shall insert the addendum behind the cover page of the Tender Documents.

QUESTION & ANSWER:

1. On the drawings for the pedestrian bridge there is a note that says bridge (By Others).
Is the pedestrian bridge being supplied and installed by the General Contractor?

Delete "By Others". The bridge is to be supplied and installed by the successful Bidder.

2. Is an aluminum bridge acceptable alternate?

No aluminum is not acceptable. Please refer to item #3 in the Construction notes that the abutment arrangement and design are based on a pre-engineered superstructure design by Eagle Bridge.

Except for the contents of this addendum, all other terms and conditions of this tender remain the same.

END OF ADDENDUM NO. 1

Yours truly,

THE CORPORATION OF THE CITY OF WINDSOR

Elaine Castellan

Elaine Castellan
Purchasing Supervisor

EC/sf

**ADDENDUM NO. 1
TENDER NO. 65-19
HAWTHORNE PEDESTRIAN BRIDGE CONSTRUCTION**

April 12, 2019

I hereby acknowledge receipt of Addendum No. 1 to the Tender No. 65-19 (2 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the _____ day of _____, 20_____.

Signature

Name (Printed)

Company Name

***NOTE: You are required to acknowledge this addendum with your TENDER submission.**

**PLEASE FAX BACK TO (519) 255-9891 OR E-MAIL @ purchasing@citywindsor.ca SIGNED
ACKNOWLEDGEMENT SHEET ASAP**

Attn: Purchasing Department