



**THE CORPORATION OF THE CITY OF WINDSOR  
OFFICE OF THE CITY SOLICITOR**

**ALEX VUCINIC**  
**Manager of Purchasing**

**Elaine Castellan**  
**Purchasing Supervisor**

**(519) 255-6272**  
**TELEPHONE NUMBER**

---

**ADDENDUM NO. 7  
TENDER NO. 65-19  
HAWTHORNE PEDESTRIAN BRIDGE CONSTRUCTION**

**May 7, 2019**

---

This addendum amends and forms part of the Tender Documents. The bidder shall insert the addendum behind the cover page of the Tender Documents.

**QUESTIONS & ANSWERS / CLARIFICATIONS:**

- 1) Please confirm the municipal appendix of OPSS 906 will be invoked.

Confirmed.

- 2) It was noted in Addendum 2 that steel decking shall be galvanized due to availability. Please confirm that weathering or galvanized steel decking will be accepted, if weathering steel is available and/or in stock.

We have no preference as long as it has anti-slip properties, which will allow roller blades and bikes to cross.

- 3) In Addendum 6, it was noted that materials shall be as specified in OPSS 906. OPSS 906 allows the substitution of A588 material for 350A. Attached is comparison table of 350A & A847. As the bridge designer, we design for the tolerances in the material grade used. Lastly, 350A steel is more difficult to source within the timelines of the project. Please confirm ASTM 847 steel is accepted.

Please proceed in accordance with OPSS 906.

- 4) Given the location of the project, the minimum mean daily temperature is -22 °C. Please confirm per S6-14, material can be tested to 27J and -20 °C (CAT2) requirement.

Confirmed.

- 5) Our supplier can only offer A500 for the structural members of the pedestrian bridge, would this be adequate, or G40.21 50W?

Weathering steel is to be used on this project. CSA G40.21 Grade 350A is permitted under OPSS 906.

- 6) Iron Bridge Fabrication requests approved equal for the bridge super structure for Hawthorne Pedestrian bridge.

The request for Approved Equal by Iron Bridge Fabrication is not approved due to the bridge not meeting specifications of abutment walls.

**Except for the contents of this addendum, all other terms and conditions of this tender remain the same.**

**END OF ADDENDUM NO. 7**

Yours truly,

**THE CORPORATION OF THE CITY OF WINDSOR**

*Elaine Castellan*

Elaine Castellan  
Purchasing Supervisor

EC/sf

---

**ADDENDUM NO. 7  
TENDER NO. 65-19  
HAWTHORNE PEDESTRIAN BRIDGE CONSTRUCTION**

**May 7, 2019**

---

I hereby acknowledge receipt of Addendum No. 7 to the Tender No. 65-19 (3 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_\_.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Name (Printed)

\_\_\_\_\_  
Company Name

**\*NOTE: You are required to acknowledge this addendum with your TENDER submission.**

**PLEASE FAX BACK TO (519) 255-9891 OR E-MAIL @ [purchasing@citywindsor.ca](mailto:purchasing@citywindsor.ca) SIGNED  
ACKNOWLEDGEMENT SHEET ASAP**

**Attn: Purchasing Department**