



**THE CORPORATION OF THE CITY OF WINDSOR
OFFICE OF THE CITY SOLICITOR**

ALEX VUCINIC

Manager of Purchasing

Elaine Castellan

Purchasing Supervisor

(519) 255-6272

TELEPHONE NUMBER

**ADDENDUM NO. 3
TENDER NO. 66-19
McHUGH PEDESTRIAN BRIDGE CONSTRUCTION**

April 17, 2019

This addendum amends and forms part of the Tender Documents. The bidder shall insert the addendum behind the cover page of the Tender Documents.

CLARIFICATION:

Addendum 2 states, “The steel decking shall be weathered steel.”

Change to: The steel decking shall be anti-slip galvanized steel.

This change is due to the limited availability of weathered steel decking.

Except for the contents of this addendum, all other terms and conditions of this tender remain the same.

END OF ADDENDUM NO. 3

Yours truly,

THE CORPORATION OF THE CITY OF WINDSOR

Elaine Castellan

Elaine Castellan
Purchasing Supervisor

EC/sf

**ADDENDUM NO. 3
TENDER NO. 66-19
McHUGH PEDESTRIAN BRIDGE CONSTRUCTION**

April 17, 2019

I hereby acknowledge receipt of Addendum No. 3 to the Tender No. 66-19 (2 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the _____ day of _____, 20_____.

Signature

Name (Printed)

Company Name

***NOTE: You are required to acknowledge this addendum with your TENDER submission.**

**PLEASE FAX BACK TO (519) 255-9891 OR E-MAIL @ purchasing@citywindsor.ca SIGNED
ACKNOWLEDGEMENT SHEET ASAP**

Attn: Purchasing Department