



**THE CORPORATION OF THE CITY OF WINDSOR  
OFFICE OF THE CITY SOLICITOR**

**ALEX VUCINIC**

**Manager of Purchasing**

**Elaine Castellan**

**Purchasing Supervisor**

**(519) 255-6272**

**TELEPHONE NUMBER**

---

**ADDENDUM NO. 1  
TENDER NO. 107-20  
REFURBISHMENT OF PRIMARY SETTLING TANK #2 LAUNDER AT LOU ROMANO  
WATER RECLAMATION PLANT**

**July 30, 2020**

---

This addendum amends and forms part of the Tender Documents. The bidder shall insert the addendum behind the cover page of the Tender Documents.

**PLEASE NOTE: The closing date has been extended to **ELEVEN-THIRTY FIFTY-NINE (11:30:59) A.M. (E.D.T.), WEDNESDAY, AUGUST 5<sup>th</sup>, 2020.****

**MANDATORY SITE VISIT:**

As the site visit was marked as “recommended” on Biddingo, the specified mandatory site visit in the tender specifications and notification letter has been changed to **NON-MANDATORY.**

**QUESTIONS/ANSWERS:**

**ITEM  
No.**

**DESCRIPTION**

A1-1

*Is the Contractor required to repair the surface cracks found on the outside wall?*

Response: The existing saw cut on the outside wall that was used for terminating the existing coating is to be filled using the repair mortar specified under the detailed specification for the applicable system. Random surface cracking is to be repaired as noted in the clause for surface preparation in the detailed specification for the applicable system.

A1-2

*Who is responsible for the disposal of the waste generated from the removal of the existing coating?*

Response: The Contractor is to include all costs associated with the disposal of waste generated during the performance of their work in the total tender cost.

**ITEM  
No.**

**DESCRIPTION**

A1-3

*There have been several requests by coating suppliers to be added to the specification as "Approved Equal" under Section 09830, Launder Protective Coating.*

Response: The tender price is to be based on one of the three listed systems in the specification. If the successful bidder would like to propose an "Approved Equal" it will be evaluated as noted in Specification Section 01600, Clause 1.5, Substitutions and Approved Equal Items.

Except for the contents of this addendum, all other terms and conditions of this tender remain the same.

***END OF ADDENDUM NO. 1***

Yours truly,

**THE CORPORATION OF THE CITY OF WINDSOR**

*Elaine Castellan*

Elaine Castellan  
Purchasing Supervisor

EC/jm

---

**ADDENDUM NO. 1  
TENDER NO. 107-20  
REFURBISHMENT OF PRIMARY SETTLING TANK #2 LAUNDER AT LOU ROMANO  
WATER RECLAMATION PLANT**

**July 30, 2020**

---

I hereby acknowledge receipt of Addendum No. 1 to the Tender No. 107-20 (3 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_\_.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Name (Printed)

\_\_\_\_\_  
Company Name

**\*NOTE: You are required to acknowledge this addendum with your TENDER submission.**

**PLEASE E-MAIL @ [purchasing@citywindsor.ca](mailto:purchasing@citywindsor.ca) SIGNED ACKNOWLEDGEMENT SHEET  
ASAP**

**Attn: Purchasing Department**