



**THE CORPORATION OF THE CITY OF WINDSOR  
OFFICE OF THE CITY SOLICITOR**

**ALEX VUCINIC**  
**Manager of Purchasing**

**Elaine Castellan**  
**Purchasing Supervisor**

**(519) 255-6272**  
**TELEPHONE NUMBER**

---

**ADDENDUM NO. 1  
TENDER NO. 133-20  
HAWTHORNE PEDESTRIAN BRIDGE CONSTRUCTION**

**November 6, 2020**

---

This addendum amends and forms part of the Tender Documents. The bidder shall insert the addendum behind the cover page of the Tender Documents.

**QUESTIONS & ANSWERS:**

1. Will the City allow for third party weld inspection after the bridge is fabricated, in replacement of employing Certified Welding Inspector (CWI)?

The CWI's role is to carry out Quality Control during fabrication. Employing an inspector to check the welds after fabrication will only provide Quality Assurance and not Quality Control. Therefore the CWI should be present during the complete fabrication of the bridge.

2. Please confirm the municipal appendix of OPSS 906 applies.

The municipal appendix applies.

3. Please confirm ASTM 847 HSS weathering steel is acceptable.

ASTM 847 weathering steel is acceptable as long as the bridge is designed accordingly, to the relevant steel strength and grade.

4. Due to steel market conditions, Category 3 and 2 weathering steel is unavailable. Please confirm Category 1 is acceptable.

Category 1 is acceptable.

5. Will the City allow timber deck alternative to the weathering or galvanized steel shown?

Decking shall not be timber. Galvanized steel is preferred over weathering steel due to greater durability.

**Except for the contents of this addendum, all other terms and conditions of this tender remain the same.**

**END OF ADDENDUM NO. 1**

Yours truly,

**THE CORPORATION OF THE CITY OF WINDSOR**

*Elaine Castellan*

Elaine Castellan  
Purchasing Supervisor

EC/sf

---

**ADDENDUM NO. 1  
TENDER NO. 133-20  
HAWTHORNE PEDESTRIAN BRIDGE CONSTRUCTION**

**November 6, 2020**

---

I hereby acknowledge receipt of Addendum No. 1 to the Tender No. 133-20 (3 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Name (Printed)

\_\_\_\_\_  
Company Name

**\*NOTE: You are required to acknowledge this addendum with your TENDER submission.**

**PLEASE RETURN SIGNED ACKNOWLEDGEMENT SHEET ASAP**  
**BY E-MAIL TO: [purchasing@citywindsor.ca](mailto:purchasing@citywindsor.ca)**