



ALEX VUCINIC
Manager of Purchasing

Elaine Castellan
Purchasing Supervisor

(519) 255-6272
TELEPHONE NUMBER

ADDENDUM NO. 4
TENDER NO. 54-21
DOUGALL AVENUE REHABILITATION –
OUELLETTE PLACE TO EUGENIE STREET WEST

March 16, 2021

This addendum amends and forms part of the Tender Documents. The bidder shall insert the addendum behind the cover page of the Tender Documents.

QUESTION/ANSWERS:

Question #1:

We have reviewed the Toxicity Characteristic Leaching Procedure (TCLP) in the soils report – section 5.13. There is no mention of Electrical Conductivity (EC) or Sodium Adsorption Ratio (SAR) in the report. Contractors require this information during the bidding process in order to evaluate where excess material can be deposited. Will the full environmental soils report be completed, based on the Total Volume of Excess Soil removed from the site, before commencement of the project? The report would be needed 3-4 weeks before the start of the project for review and implementation.

Answer: It is reasonable to assume that EC and SAR (typically an indication of salts) may be present in the excess materials as salts are used for de-icing the roadway for traffic, vehicular, and/or pedestrian traffic safety in winter conditions. The excess material therefore, may be re-used in locations with similar uses e.g. where paved surfaces are to be constructed and de-icing salt applications may be expected. Commission of further report is on the contractor discretion.

Question#2:

In order to be able to price the MH rehabilitation items below we need to know the dimensions , Depths and configurations for the MH's , Please advice ?

4		Using cured-in-place pipe installation, rehabilitate existing Sewer Manholes, in accordance with Ontario Provincial Standard Specification (OPSS) 460, including pre and post-lining video inspection. (Provisional)	9.0	Each	\$	\$
---	--	---	-----	------	----	----

Answer: Please consider the following

Sewemain Size (mm)	Manhole Size (mm)	Depth
525	1200	As per Drawings
600	1200	As per Drawings
1200	2400	As per Drawings

Question #3:

As per addendum 2 Question 1 CCTV videos for the existing pipes to be lined are available , would you please send us those videos to enable us evaluate the amount of prepping and cleaning involved .

Answer: Please use the following link:

<https://citywindsorca.kiteworks.com/w/dwD90nemnTa0nucFSoTUnEvJWt0NtWhmSZwBXi5nkpQZ6>

Except for the contents of this addendum, all other terms and conditions of this tender remain the same.

END OF ADDENDUM NO. 4

Yours truly,

THE CORPORATION OF THE CITY OF WINDSOR

Elaine Castellan

Elaine Castellan
Purchasing Supervisor
EC/jm

**ADDENDUM NO. 4
TENDER NO. 54-21
DOUGALL AVENUE REHABILITATION –
OUELLETTE PLACE TO EUGENIE STREET WEST**

March 16, 2021

I hereby acknowledge receipt of Addendum No. 4 to the Tender No. 54-21 (3 pages).

The information contained therein is hereby noted and account of same will be taken in our tender cost.

This information was received on the _____ day of _____, 20_____.

Signature

Name (Printed)

Company Name

***NOTE: You are required to acknowledge this addendum with your TENDER submission.**

**PLEASE E-MAIL @ purchasing@citywindsor.ca SIGNED ACKNOWLEDGEMENT SHEET
ASAP**

Attn: Purchasing Department