



### PEGGING OF SODS

MINIMUM SIZE OF STAKES-1"X1" NOMINAL X 12" (LONGER IF NECESSARY TO SECURE SODS.)

ON SLOPES STEEPER THAN 13/4:1 EVERY SOD SHALL BE STAKED.  
ON SLOPES OF 13/4:1 TO 3:1 EVERY SOD SHALL BE STAKED IN THE BOTTOM THREE ROWS & IN EVERY THIRD ROW ABOVE.

STAKES SHALL BE DRIVEN FLUSH BUT NOT DEEPER.

THE SPACE BETWEEN STAKES REGARDLESS OF SOD SIZE SHALL NOT EXCEED 24" ACROSS THE FACE OF THE SLOPE.

### NOTES :

1. ON PREPARED SLOPE, WHERE DESIGNATED BY THE ENGINEER, WIRE MESH SHALL BE STRETCHED FROM TOP TO BOTTOM OF THE SLOPE AND SHALL BE SECURED BY WIRING WITH NO.9 TIE WIRE TO CEDAR POSTS SUNK 3 FT. 6 IN. INTO THE GROUND AT INTERVALS ACROSS THE SLOPE NOT EXCEEDING 3 FT. 6 IN.
2. ONE ROW OF POSTS SHALL BE PLACED AT THE TOP OF SLOPE, ONE ROW AT THE BOTTOM OF SLOPE AND INTERMEDIATE ROWS AT MAXIMUM DISTANCE OF 16 FT. UP OR DOWN THE SLOPE.
3. THE METHOD OF WIRING THE MESH TO THE POSTS SHALL BE SO ARRANGED AS TO PERMIT THE LOOP TO MOVE DOWN THE POST AS THE FILL SETTLES.
4. THE POSTS SHALL BE CUT OFF AT SOD LEVEL.
5. SODDING IS TO EXTEND TO EDGE OF ROUNDING AND TO BE COUNTERSUNK TO EXISTING GRADE LEVEL AT EDGES OF SHOULDERS AND DITCHES TO ALLOW FREE FLOW OF WATER ACROSS THE JOINT BETWEEN EXISTING GRADE & NEW SODDING.
6. SEE STANDARD SPECIFICATION S-14.

NOT TO SCALE

CITY OF WINDSOR DEPARTMENT OF PUBLIC WORKS	
<b>SODDING OF SIDE SLOPES</b>	
DRAWN BY: D.I.H.	DATE: MAY 1975
REVISION :	CHECKED BY: <i>[Signature]</i>
CHECKED BY: <i>[Signature]</i>	PASSED BY: <i>[Signature]</i>
<i>H. Payne</i> COMMISSIONER OF WORKS	
AS-205	