

NOTES:

1. UTILITY CUT RESTORATION AS PER CITY OF WINDSOR STANDARD SPECIFICATION S-29.
2. UNSHRINKABLE BACKFILL AS PER CITY OF WINDSOR STANDARD SPECIFICATION S-24.
3. CONCRETE AS PER CITY OF WINDSOR STANDARD SPECIFICATION S-9.
4. GRANULAR 'A' MATERIAL AS PER CITY OF WINDSOR STANDARD SPECIFICATION S-4.
5. CONCRETE THICKNESS TO MATCH EXISTING ADJACENT CONCRETE PANELS BUT NOT LESS THAN 150MM.
6. LOAD TRANSFER DEVICES AND DOWELING TO MATCH EXISTING ADJACENT PAVEMENT.
7. BEDDING AND COVER MATERIAL AROUND UTILITY TO BE AS PER THE UTILITY'S SPECIFICATION REQUIREMENTS.


TEMPORARY SURFACE REINSTATEMENT TO BE 50MM COLD MIX OR HOT MIX ASPHALT OVER UNSHRINKABLE BACKFILL OR GRANULAR 'A'.



CITY OF WINDSOR

DEPARTMENT OF PUBLIC WORKS

UTILITY RESTORATION FOR CONCRETE PAVEMENT

DR'N BY: M.M.	DATE: JUNE, 1975
REVISION: AUGUST, 2012	CH'KD BY: A.L
CH'KD BY:	PASSED BY:
 CITY ENGINEER	AS-207A