


NOTES

1. HOLE DIMENSIONS ARE FROM TOP OF POLE EXCEPT AS NOTED.
2. HOLES SHALL BE 19mm DIAMETER
3. POLE TOP DIAMETER SHALL BE 121mm WITH FLAT TOP.
4. POLE SHALL BE ROUND
5. POLE SHALL BE CLASS 'B'
6. CONCRETE POLE SHALL BE SPUN TO C.S.A. STANDARDS A14.1-1965



7.62m CONCRETE OR FIBREGLASS POLE
N.T.S.

CITY OF WINDSOR DEPARTMENT OF PUBLIC WORKS	
STANDARD RESIDENTIAL STREET LIGHT (TYPE 1)	
DR'N BY: E. STERGIU	DATE: MAY 1980
REVISION: <i>com</i>	CH'KD BY: <i>AA</i>
CH'KD BY: <i>Pelle</i>	PASSED BY: <i>AA</i>
<i>A. H. Mack</i> COMMISSIONER OF WORKS	
AS-509	