


CROSS SECTION

N.T.S.

GENERAL NOTES:

- 1.) THIS DETAIL SHALL APPLY TO DOWNSPOUTS ADJACENT TO HARD SURFACES WHERE SPLASH BLOCKING IS NOT PERMITTED.
- 2.) SOLID PVC PIPE SHALL EXTEND A MINIMUM OF 600mm(2'-0") BEYOND ALL HARD SURFACES.
- 3.) 100mm(4") PVC PIPE TRENCH TO BE BACKFILLED WITH 150mm(6") OF 20mm(3/4") CLEAR STONE AND LINED WITH NON-WOVEN GEOTEXTILE FILTER FABRIC.
- 4.) THE CHIEF BUILDING OFFICIAL AND CITY ENGINEER MAY APPROVE ALTERNATIVE DETAILS DEPENDING ON SITE SPECIFIC SOIL CONDITIONS AND OTHER CIRCUMSTANCES.

CITY OF WINDSOR	
ENGINEERING DEPARTMENT	
DOWNSPOUT DISCHARGE ADJACENT TO HARD SURFACING	
DR'N BY: M.L.R/A.C.	DATE: JULY, 2021
REVISION:	CH'KD BY: P.W.
CH'KD BY: P.J.U.	PASSED BY:
 MARK WINTERTON, CITY ENGINEER	
AS-562	